

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1574:159 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ, 07004-1561
Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

DESIGN: Model **Uni-Com** digital alarm communicator transmitter with Model ABS-8R (optional) enclosure. The unit is used to transmit system status to central station via a standard two-wire telephone switching network. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 21.2-28.2 VDC

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as digital alarm communicator transmitter for use with separately listed compatible fire alarm control units.

NOTE: Formerly 7300-0085:173

XLF: 7300-0028:174

05-20-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 23, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager